



The State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES



Robert R. Scott, Commissioner

June 12, 2018

IMMEDIATE ACTION REQUIRED

MARLIS DUBE
SOLAR VILLAGE ASSN
54 SILKWOOD AVE
BELMONT NH 03220

SUBJECT: Town: BELMONT- Public Water System: SOLAR VILLAGE
PWS ID: 0203060
BOIL WATER ORDER

Dear Owner:

This letter will serve to confirm the conversation with Marlis on June 12, 2018, concerning the requirement that a **BOIL WATER ORDER** be issued immediately for the subject public water system. The Boil Order is being required by the Department of Environmental Services ("DES") today because of loss of pressure. This situation may have introduced harmful bacteria, including fecal coliform/*E. coli* bacteria, into the water system.

Pursuant to NH Administrative Rule Env-Dw 801, the Boil Order Notice must be issued as soon as possible, but not later than 24 hours after the water system became aware of a situation that may have compromised the safety of the drinking water. The Boil Order will not be lifted until 2 consecutive sets of samples taken at least 24 hours apart show the absence of total coliform bacteria and DES' technical staff is satisfied that all reasonable efforts have been made to correct the problem and assure that the water is safe for consumption.

Public Notice Forms are available by going to www.des.nh.gov; click on "A to Z List" and select "Public Notice (for Public Water Systems)" then choose "Acute PN- Boil Order (Precautionary)." You may, if you wish, add additional pertinent information. Please submit a copy of the boil order notice to this office within 10 days of the date of this letter along with a completed certification form.

If you have any questions, please contact me by phone at (603) 271-0672 or email me at Jacqueline.Howarth@des.nh.gov.

Questions regarding the lifting of the boil order may be addressed to Shelley Frost at (603) 271-2949 or Shelley.Frost@des.nh.gov

Sincerely,

Jacqueline Howarth
Drinking Water and Groundwater Bureau

cc: File
ec: Health Officer, Town of Belmont
Brian McCall, Primary Operator
USEPA Region 1

Posted on NHDES Drinking Water Advisory webpage found at www.des.nh.gov